



1. ALL EXTERIOR DEVICES TO BE WEATHERPROOF.
2. PROVIDE ALL EMPTY CONDUITS WITH PULL STRING AND CAP AT BOTH ENDS.
3. ALL WIRING OUTSIDE SHALL BE A MINIMUM OF #10 COPPER WITH TYPE 'XHHW-2' INSULATION. FOR UNDERGROUND CIRCUITS RUN IN P.V.C., PROVIDE A #10 COPPER BOND IN ADDITION TO CIRCUIT CONDUCTORS.
4. SEAL ALL CONDUIT PENETRATING THE BUILDING WALLS

1	NEW 400/400A DISCONNECT
2	J-BOX FOR CARWASH PAYMENT AND ENTRY BOX
3	PROPOSED LOCATION FOR NEW PANEL CW
4	(2) 2" UNDERGROUND CONDUIT FOR NEW CARWASH SERVICE. PANEL CW
5	(1) 1" UNDERGROUND CONDUIT FOR NEW CARWASH SING

COPYRIGHT NOTICE
This drawing is the property of the above referenced Professional and is not to be used for any purpose other than the specific project and site named herein, and cannot be reproduced in any manner without the express written permission from the Professional.

DATE	DESCRIPTION
01/19/15	PERMIT SET

PROFESSIONAL SEAL

GUIDO INOA ALVAREZ

PROJECT MANAGER

GUIDO INOA ALVAREZ

QUALITY CONTROL

GUIDO INOA ALVAREZ


DRAWN BY

FREDDY LEE

**CIRCLE K
STORES, INC.
CAR WASH**

COLORADO SPRINGS
COLORADO

E. FOUNTAIN BLVD & ACADEMY PARK LOOP



CIRCLE K STORES INC.

20130780

SHEET TITLE
ELECTRICAL
SITE PLAN

E1.0-CW