

B. PROVIDE WALL OUTLETS IN 4" SQUARE 2-1/8" DEEP BOX WITH RAISED SINGLE GANG COVERS EQUIPPED WITH BLANK STAINLESS STEEL DEVICE PLATES. EXTEND 3/4" EMPTY CONDUIT FROM EACH OUTLET TO THE CEILING SPACE AND TERMINATE WITH INSULATED BUSHINGS. PROVIDE NYLON PULL WIRE IN ALL CONDUITS LEFT EMPTY.

-0.1°C/vv

FOR BID ONLY