

S. GROUND, PHASE AND NEUTRAL CONDUCTORS SHALL BE PIG-TAILED IN OUTLET BOXES OR MULTI-OUTLET ASSEMBLY FOR RECEPTACLES SO THAT GROUND AND ELECTRICAL SERVICE WILL NOT BE DISTURBED TO OTHER RECEPTACLES ON THE SAME MULTI-WIRE CIRCUIT IF RECEPTACLE IS REMOVED.

E. ALL PLASTIC DIFFUSERS SHALL BE 100 PERCENT VIRGIN ACRYLIC (NOMINAL .125 INCH THICK) AND ALL LEXAN DIFFUSERS SHALL

B. PROVIDE WALL OUTLETS IN 4" SQUARE 2-1/8" DEEP BOX WITH RAISED SINGLE GANG COVERS EQUIPPED WITH BLANK STAINLESS STEEL DEVICE PLATES. EXTEND 3/4" EMPTY CONDUIT FROM EACH OUTLET TO THE CEILING SPACE AND TERMINATE WITH INSULATED BUSHINGS. PROVIDE NYLON PULL WIRE IN ALL CONDUITS LEFT EMPTY.

**FOR BID ONLY**